QEP Range



Genset Image	for illustration	purposes only

Power ratings			
Prime	Prime	Standby	Standby
kW	kVA	kW	kVA
9.1	10.0	10.7	11.9
Power facto	or		0.9

Fuel consumption table

Load level	PRIME	Aut. (h)
	(L/h)	
75%	4.23	5.67
100%	5.64	4.26



i ci ioi illunice ciuss		GI	
Acoustic pressure LpA a 7 m	(dB(A) @7m)	68	
Acoustic power LwA	(dB(A))	96	
Mechanical structure			
Length (L)	(mm)	960	
Width (W)	(mm)	641	
Height (H)	(mm)	667	
Weight	(kg)	188	

Technical data

(V)

(Hz)

230

50

Gasoline G1

24

Optional

Dimensions


Fuel tank capacity

Wheels and handles

Voltage

Fuel

Frequency



Engine

Gen	eral	
Engine Brand		Honda
Engine Model		GX630
R.P.M.		3000
Net Power	(kWm)	12.00
Fuel		Gasoline
No. of cylinders		2
Displacement	(cm³)	688
Regulation type		Mechanical
Emission level		Stage V

Lubrication	System	
Oil capacity	(1)	1.9
Engine Oil Guard		YES

Cooling S	ystem
Cooling type	Air

Starting syste	em
Recoil	NO
Electric 12V	YES

Alternator

Alternator brand	Mecc Alte
Alternator model	S20FS-160/A + AV
IP alternator	IP23
Peak power 163°/27°	(kVA) 10,80
Poles	2
Excitation system	Capacitor + AVR Brushless
Efficiency at 100% 125°/40°	(%) 79.2

8170023240
Please, contact your local Atlas Copco Dealer for more information

QEP R12 HP S5 50 230 ACDE 2019EN4.0



Main features and options

Mains features

- Electrical key start (E)
- Large fuel tank
- Engine Oil Guard
- Automatic Voltage Regulation (A)
- Magnetothermal protection
- Instrumentation, voltmeter, hourmeter
- Differential circuit breaker (D)
- Connector for remote start (C)
- Sockets
- CE noise compliance

Sockets configuration

SCHUKO 230V 16A IP54 1 2P+T CEE 230V 16A IP44 1 2P+T CEE 230V 32A IP44 1

Options

- Wheel kit
- ATB (Automatique Transfer Box) with AMF (Automatique start on Mains Failure) including connector
- Remote Start and Stop Wireless with connector

Regulations:

The generator set has a CE Marking that includes the following directives:

- 2006/42/CE Machine Safety.
- 2014/35/CE Low Voltage.
- 2014/30/CE Electromagnetic compatibility.
- 2005/88/CE Noise emission in the environment by equipment for use outdoors.
- 2016/1628/CE Gases and contaminating particles emissions.

Definitions

Prime Rating

PRIME POWER: Electrical power data available at a variable load without limits of hours per year. An overload of 10 % is allowed for 1 hour of every 12. In accordance with ISO 8528/1 (2005) - PRP

STANDBY POWER: Electrical power data at variable load in an emergency in accordance with standard ISO 8528/1 (2005) – ESP. Overloads of emergency power are not allowed.

Grupos Electrógenos Europa, S.A. is a certified company with ISO 9001, ISO 14001, OHSAS 18001 and PECAL

Atlas Copco reserves the right to modify any characteristic of their equipment without prior warning.

All products are designed and engineered in Zaragoza Competence Center

Weight and dimensions of a standard generator set.

Non-contractual document

Grupos Electrógenos Europa, S.A.

Central Offices:

8170023240

Polígono pitarco II - Parcela 20 50450 Muel (Zaragoza) España Tel.: +34 976 145 432

Fax.: +34 976 145 431

DISTRIBUTED BY:

Please, contact your local Atlas Copco Dealer for more information

QEP R12 HP S5 50 230 ACDE 2019EN4.0

